

**HTT Flooring - Duro Hybris 5+2mm Range - Wet Sliptest SN170723-3**

17 Jul 2023

**Slip Resistance Classification of New Pedestrian Surfaces - AS4586:2013**

This Test Report Is In Accordance with Appendix A	Wet Pendulum Test
Date Tested:	17 Jul 2023
Test Report Number:	SN170723-3
Client Name & Billing Address:	HTT Flooring Pty Ltd - Unit 2, 8 Gunya Street Regents Park NSW 2143
Project Name or Test Location:	HTT Flooring Showroom - 1b/42-44 Birnie Ave Lidcombe NSW 2141
Surface Tested :	Duro Hybris 5+2mm Range - 5 Colours
<i>Samples and Test Information Supplied by Client</i>	
Wet Pendulum Test carried out using :	Slider 96 (4S) Rubber slider
Testing Officer / Approved Signatory:	Shenea Neill
Pendulum in use - Calibration Date :	#1133 - Munro-Stanley Portable Skid Tester (C : 14.10.21)
Signature of Approved Signatory :	

**Test Results :**

Sample No.	Swing 1	Swing 2	Swing 3	Swing 4	Swing 5	Mean BPN of last 3 swings :	SCV :	Surface Picture
Blackbutt	46	46	45	45	45	45	N/A	
Classic Navy	51	51	51	50	50	50	N/A	

Sample No.	Swing 1	Swing 2	Swing 3	Swing 4	Swing 5	Mean BPN of last 3 swings :	SCV :	Surface Picture
Mediterranean	55	55	54	54	54	54	N/A	
Magnolia	54	53	52	52	52	52	N/A	
Japandi	50	49	48	48	48	48	N/A	

Reported SRV For Test Area : 50

CLASSIFICATION using Slider 96 (4S Slider) P4 = 45 - 54

*Accredited for Compliance with ISO/IEC 17025. The information presented herein and on the Sliptest Report is copyright and is protected by copyright law, any reproduction of this information and test report except in full is prohibited. Sliptest Australia Pty. Ltd. performed this on site test with reference to the following Australian Standard testing criteria, of AS 4586:2013 Classification of new pedestrian surface materials. Appendix A - Wet Pendulum Test Method and Hand Book HB 198: 2014 with reference to AS/NZS 4663: 2004 Slip Resistance measurement of existing pedestrian surfaces and HB 197: 1999. These results do not account for Future Wear, Maintenance or Contamination of this surface once in-situ.*

Page 1 of 1 - END OF REPORT