

# VOC Content Test Certificate

Tuesday, 22 November 2022

**Supplier** Theta Work Pty Ltd (1b/ 42 Birnie Ave, Lidcombe, NSW, 2141, Australia)

**Sample Description** Estrobond A80.

**Date Tested** 18 November 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

**Test Method** ASTM D3960 & ASTM D2369 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from the Green Building Council of Australia.

## Test Data

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Design &amp; As Built V1.3-13.1.1B</b> <b>Green Star Interiors V1.3-12.1.1B</b>	<b>ESTROBOND A80</b>
<b>Wood Flooring and Laminate Adhesives and Sealants</b> <b>Limit: 100 grams per liter</b>	<b>47 grams per litre as VOC content per material</b>
<b>Meets GBCA VOC Content Requirement</b>	<b>Yes</b>



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant



Dr. Tuan Duong  
 PhD, BE (Chem. Eng.)  
 Senior Consultant



Travis Hale  
 BSc (Biotechnology)  
 Senior Consultant

Date of issue: 22/11/2022.

Date of Expiry: 22/11/2027.

P22110056