



HTT FLOORING - Guardian SPC 6.5mm Sample - Wet Sliptest SN041120-12

04 Nov 2020

Slip Resistance Classification of New Pedestrian Surfaces - AS4586:2013 Appendix A

Date Tested:	04 Nov 2020
Test Report Number:	SN041120-12
Client Name & Address:	HTT Flooring Pty Ltd - Unit 2, 8 Gunya Street Regents Park NSW 2143
Test Site / Surface Tested :	Guarding SPC - 6.5mm
Sample Information :	Samples and Test Information Supplied by Client
Wet Pendulum Test carried out using :	Slider 96 (4S) Rubber slider
Testing Officer :	Shenea Neill
Testing Officer :	#1133 - 31.10.2019 - Munro-Stanley Portable Skid Tester
Testing Officer Signatory:	

Test Results :

Sample No.	Swing 1	Swing 2	Swing 3	Swing 4	Swing 5	Mean BPN of last 3 swings :	SCV :	Surface Picture
Sample 1	50	50	48	48	48	48	N/A	
Sample 2	49	49	48	48	48	48	N/A	
Sample 3	46	46	45	45	45	45	N/A	
Sample 4	48	48	48	47	47	47	N/A	
Sample 5	47	47	46	46	46	46	N/A	

Variation to Standard Mean BPN Slip Resistance Value (SRV) 47

CLASSIFICATION using Slider 96 (4S Slider) P4 = 45 - 54

Accredited for Compliance with ISO/IEC 17025. The information presented herein and on the Sliptest Report is copyright and is protected by copyright law, any reproduction of this information and test report except in full is prohibited. Sliptest Australia Pty. Ltd. performed this on site test with reference to the following Australian Standard testing criteria, of AS 4586:2013 Classification of new pedestrian surface materials. Appendix A – Wet Pendulum Test Method and Hand Book HB 198: 2014 with reference to AS/NZS 4663: 2004 Slip Resistance measurement of existing pedestrian surfaces and HB 197: 1999. These results do not account for Future Wear, Maintenance or Contamination of this surface once in-situ.

Page 1 of 1 - END OF REPORT